

Title: Preliminary Post Incident Review (PIR) - Multiple services recovering after power/cooling issue - Australia East

Tracking ID: [VVTQ-J98](#)

Event Type: Service Issue

Status: Resolved

Service(s): Azure Relay, Azure Purview, Azure Health Data Services, Virtual Machines, Azure Container Apps, Backup, IoT Central, Azure Cosmos DB, Azure Data Explorer, Event Hubs, Azure Arc enabled Kubernetes, Azure Database for MySQL flexible servers, ExpressRoute \ ExpressRoute Circuits, Stream Analytics, Azure Chaos Studio, API Management, Log Analytics, Application Insights, ExpressRoute \ ExpressRoute Gateways, Azure NetApp Files, Azure Databricks, SQL Database, Service Fabric, Azure IoT Hub, Azure Digital Twins, Notification Hubs, Azure Kubernetes Service (AKS), Logic Apps, Data Factory, Network Infrastructure, Service Bus, App Service, Azure Search, Azure API for FHIR, Batch, Storage, Container Registry, Azure Database for PostgreSQL flexible servers, HDInsight, Redis Cache, Device Update for IoT Hub

Region(s): Australia East, Australia Southeast

Start time: 2023-08-30T09:00:00.373Z

Resolve time: 0000-12-31T13:55:08.000Z

Last update time: 2023-09-02T04:30:43.293Z

Impacted subscriptions: fe4a62bd-9f59-4d84-903b-0ff05610f075,
46995d20-05a1-49c1-a8b3-83753d6ec980

Last update:

This is our "Preliminary" PIR that we endeavor to publish within 3 days of incident mitigation, to share what we know so far. After our internal retrospective is completed (generally within 14 days) we will publish a "Final" PIR with additional details/learnings.

What happened?

Between approximately 08:41 UTC on 30 August 2023 and 06:40 UTC on 1 September 2023 customers may have experienced issues accessing or using Azure, Microsoft 365 and Power Platform services. This event was triggered by a utility power sag in the Australia East region which tripped a subset of the cooling units offline in one datacenter, within one of the Availability Zones. While working to restore cooling, temperatures in the datacenter increased so we proactively powered down a small subset of selected compute and storage scale units, in an attempt to avoid damage to hardware.

Multiple downstream Azure services with dependencies on this infrastructure were also impacted – including Activity Logs & Alerts, API Management, App Service, Application Insights, Arc enabled Kubernetes, Azure API for FHIR, Backup, Batch, Chaos Studio, Container Apps, Container Registry, Cosmos DB, Databricks, Data Explorer, Data Factory, Database for MySQL flexible servers, Database for PostgreSQL flexible servers, Digital Twins, Device Update for IoT Hub, Event Hubs, ExpressRoute, Health Data Services, HDInsight, IoT Central, IoT Hub, Kubernetes Service (AKS), Logic Apps, Log Analytics, Log Search Alerts, Microsoft Sentinel, NetApp Files, Notification Hubs, Purview, Redis Cache, Relay, Search, Service Bus, Service Fabric, SQL Database, Storage, Stream Analytics, Virtual Machines. A small number of these services experienced prolonged impact, predominantly as a result of dependencies in recovering subsets of Storage, SQL, and/or Cosmos DB

services.

What went wrong and why?

Starting at approximately 08:41 UTC on 30 August 2023, a utility power sag in the Australia East region tripped a subset of the cooling units offline in one datacenter, within one of the Availability Zones. We performed our documented Emergency Operational Procedures (EOP) to attempt to bring the chillers back online, but were not successful. The cooling capacity was reduced in two data halls for a prolonged time, so temperatures continued to rise. At 11:34 UTC, infrastructure thermal warnings from components in the affected data halls directed a shutdown of selected compute, network and storage infrastructure – by design, to protect data durability and infrastructure health. This resulted in a loss of service availability for a subset of this Availability Zone.

The cooling capacity for the two affected data halls consisted of seven chillers, with five chillers in operation and two chillers in standby (N+2) before the voltage dip event. When the event occurred, all five chillers in operation faulted and restart because the corresponding pumps did not get the run signal from the chillers. This is important as it is integral to the successful restarting of the chiller units. In addition, faulted chillers could not be restarted manually, as the chilled water loop temperature had exceeded the threshold. We had two chillers that were in standby which attempted to restart automatically – one managed to restart and came back online, the other restarted but was tripped offline again within minutes. Subsequently, thermal loads had to be reduced by shutting down servers. This successfully allowed the chilled water loop temperature to drop below the required threshold and enabled the restoration of the cooling capacity. When the data hall temperature levels were within operational thresholds, we began to restore power to the affected infrastructure and started a phased process to bring the infrastructure back online. Once all networking and storage infrastructure had power restored, dependent compute scale units were then also restored to operation. As the underlying compute and storage scale units came online, dependent Azure services started to recover, but some services experienced issues coming back online.

From a Storage perspective, seven tenants were impacted – five standard storage tenants, and two premium storage tenants. While all storage data is replicated across multiple storage servers, there were cases in which all of the copies were unavailable due to failures on multiple impacted storage servers. After power restoration, storage nodes started coming back online from 15:25 UTC. Generally speaking, there were three main factors that contributed to delays in bringing storage infrastructure back to full functionality. Firstly, the hardware damaged by the data hall temperatures required extensive troubleshooting. Diagnostics were not able to identify the faults, because the storage nodes themselves were not online – as a result, our onsite datacenter team needed to remove components manually, and re-seat them one by one to identify which particular component(s) were preventing each node from booting. Secondly, several components needed to be replaced for successful data recovery and to restore impacted nodes. In order to completely recover data, some of the original/faulty components were required to be temporarily re-installed in individual servers. Thirdly, we identified that our automation was incorrectly approving stale requests, and marking some healthy nodes as unhealthy, which slowed storage recovery efforts.

From a SQL perspective, once power had fully returned to the impacted halls, service restoration was initially impacted by the slow recovery of dependent services, those being primarily Azure Standard Storage offerings. Many general purpose databases remained unavailable until those premium Azure Storage services had recovered. After storage services were >99% recovered, a single tenant ring that hosted databases failed to recover completely after the incident. This ring, hosting over ~250K databases had a mix of failure modes. Some databases may have been completely unavailable, some would have experienced intermittent connectivity issues, and some databases would have been fully available. This uneven impact profile for databases in the degraded ring, meant that it was difficult to summarize which customers were still impacted, which continued to present a challenge throughout the incident. As we attempted to migrate databases out of the degraded ring, SQL did not have well tested tools on hand that were built to move databases when the source ring was in degraded health scenario. Soon this became our largest impediment to mitigating impact. Our standard DB migration workflows are designed to contain many safety and health checks to make sure that the DB being migrated does not experience downtime during the migration. Each of these contact points from the SQL control plane to the

underlying Service Fabric (which hosts the DB's compute and coordinates replicas) for the ring was another opportunity for the operation to fail or get stuck. Because every DB moved required manual mitigation via scripts, it seriously undermined our ability to move fast even once impacted DBs were identified, and DB moves were scheduled.

From a Cosmos DB perspective, the service experienced a loss of compute underpinning three clusters, and a loss of the operating system for 11 clusters due to dependencies on Azure storage. In total this mean that approximately half of Cosmos DB clusters in the Australia East region were either down or heavily degraded. Eligible accounts (multi-region with Service Managed Failover enabled) were failed over to their alternate regions to restore availability. A set of internal accounts were not originally configured for failover, so the Cosmos DB team worked with these internal service teams to configure and then failover those accounts upon request. Accounts that were not eligible had service restored to partitions once the dependent storage and compute were restored and Cosmos DB clusters recovered.

How did we respond?

30 August 2023 @ 08:41 – Voltage sag occurred on utility power line
30 August 2023 @ 08:43 – Five chillers failed to restart
30 August 2023 @ 08:45 – Two standby chillers started automatically
30 August 2023 @ 08:47 – One standby chiller tripped and went offline
30 August 2023 @ 09:41 – Onsite team arrived at the rooftop chiller area
30 August 2023 @ 09:42 – Onsite team manually restarted the five chillers as per the EOP
30 August 2023 @ 10:30 – Storage and SQL alerted by monitors about failure rates
30 August 2023 @ 10:57 – Cosmos DB Initial impact detected via monitoring
30 August 2023 @ 11:15 – Attempts to stabilize the five chillers were unsuccessful after multiple chiller restarts
30 August 2023 @ 11:20 – Chiller OEM support team arrives onsite
30 August 2023 @ 11:34 – Decision was made to shutdown infrastructure in the two affected data halls
30 August 2023 @ 12:07 – Failover initiated for eligible Cosmos DB accounts
30 August 2023 @ 12:12 – Five chillers manually restarted successfully
30 August 2023 @ 13:30 – Data hall temperature normalized
30 August 2023 @ 14:10 – Safety walkthrough completed for both data halls
30 August 2023 @ 14:25 – Decision made to start powering up hardware in the two affected data halls
30 August 2023 @ 15:10 – Power restored to all hardware
30 August 2023 @ 15:25 – Storage infrastructure started coming back online after power restoration
30 August 2023 @ 15:30 – Identified three specific storage tenants still experiencing fault codes
30 August 2023 @ 16:00 – Began manual recovery efforts for these three storage tenants
30 August 2023 @ 16:13 – Account failover completed for all Cosmos DB accounts
30 August 2023 @ 19:29 – Successfully recovered all premium storage tenants
30 August 2023 @ 20:29 – All but two SQL nodes recovered
30 August 2023 @ 22:35 – Standard storage tenants were recovered, except for one scale unit
31 August 2023 @ 04:04 – Restoration of Cosmos DB accounts to Australia East initiated
31 August 2023 @ 04:43 – Final Cosmos DB cluster recovered, restoring all traffic for accounts that were not failed over
31 August 2023 @ 08:45 – All external customer accounts back online and operating from Australia
1 September 2023 @ 06:40 – Successfully recovered all standard storage tenants

How are we making incidents like this less likely or less impactful?

Based on our initial assessment, we have already identified the following learnings from a datacenter power/cooling perspective. The Final PIR will include additional learnings and repairs based on the service-specific extended recovery timelines.

Due to the size of the datacenter campus, the staffing of the team at night was insufficient to restart the chillers in a timely manner. We have temporarily increased the team size from three to seven, until the underlying issues are better understood and appropriate mitigations can be put in place.

The EOP for restarting chillers is slow to execute for an event with such a significant blast radius. We are exploring ways to improve existing automation to be more resilient to various voltage sag event types.

Moving forward, we are evaluating ways to ensure that the load profiles of the various chiller subsets can be prioritized so that chiller restarts will be performed for the highest load profiles first.

Utilizing the playbook in sequencing workload failovers and equipment shutdown could have been prioritized differently with better insights. We are working to improve reporting on chilled water temperature, to enable more timely decisions for failover/shutdown based on thresholds.

The five chillers did not manage to restart because the corresponding pumps did not get the run signal from the chillers. This is important as it is integral to the successful restarting of the chiller units. We are partnering with our OEM vendor to investigate why the chillers did not command their respective pump to start.

One standby chiller did not automatically restart due to an unknown error. Our OEM vendor is running diagnostics to understand what caused this specific issue.

How can we make our incident communications more useful?

You can rate this PIR and provide any feedback using our quick 3-question survey: <https://aka.ms/AzPIR/VVTQ-J98>

Update history:

Sat Sep 02 2023 14:30:43 GMT+1000 (Australian Eastern Standard Time)

This is our "Preliminary" PIR that we endeavor to publish within 3 days of incident mitigation, to share what we know so far. After our internal retrospective is completed (generally within 14 days) we will publish a "Final" PIR with additional details/learnings.

What happened?

Between approximately 08:41 UTC on 30 August 2023 and 06:40 UTC on 1 September 2023 customers may have experienced issues accessing or using Azure, Microsoft 365 and Power Platform services. This event was triggered by a utility power sag in the Australia East region which tripped a subset of the cooling units offline in one datacenter, within one of the Availability Zones. While working to restore cooling, temperatures in the datacenter increased so we proactively powered down a small subset of selected compute and storage scale units, in an attempt to avoid damage to hardware.

Multiple downstream Azure services with dependencies on this infrastructure were also impacted – including Activity Logs & Alerts, API Management, App Service, Application Insights, Arc enabled Kubernetes, Azure API for FHIR, Backup, Batch, Chaos Studio, Container Apps, Container Registry, Cosmos DB, Databricks, Data Explorer, Data Factory, Database for MySQL flexible servers, Database for PostgreSQL flexible servers, Digital Twins, Device Update for IoT Hub, Event Hubs, ExpressRoute, Health Data Services, HDInsight, IoT Central, IoT Hub, Kubernetes Service (AKS), Logic Apps, Log Analytics, Log Search Alerts, Microsoft Sentinel, NetApp Files, Notification Hubs, Purview, Redis Cache, Relay, Search, Service Bus, Service Fabric, SQL Database, Storage, Stream Analytics, Virtual Machines. A small number of these services experienced prolonged impact, predominantly as a result of dependencies in recovering subsets of Storage, SQL, and/or Cosmos DB services.

What went wrong and why?

Starting at approximately 08:41 UTC on 30 August 2023, a utility power sag in the Australia East region tripped a subset of the cooling units offline in one datacenter, within one of the Availability Zones. We performed our documented Emergency Operational Procedures (EOP) to attempt to bring the chillers back online, but were not successful. The cooling capacity was reduced in two data halls for a prolonged time, so temperatures continued to rise. At 11:34 UTC, infrastructure thermal warnings from components in the affected data halls directed a shutdown of selected compute, network and storage infrastructure – by design, to protect data durability and infrastructure health. This resulted in a loss of service availability for a subset of this Availability Zone.

The cooling capacity for the two affected data halls consisted of seven chillers, with five chillers in operation and two chillers in standby (N+2) before the voltage dip event. When the event occurred, all five chillers in operation faulted and restart because the corresponding pumps did not get the run signal from the chillers. This is important as it is integral to the successful restarting of the chiller units. In addition, faulted chillers could not be restarted manually, as the chilled water loop temperature had exceeded the threshold. We had two chillers that were in standby which attempted to restart automatically – one managed to restart and came back online, the other restarted but was tripped offline again within minutes. Subsequently, thermal loads had to be reduced by shutting down servers. This successfully allowed the chilled water loop temperature to drop below the required threshold and enabled the restoration of the cooling capacity. When the data hall temperature levels were within operational thresholds, we began to restore power to the affected infrastructure and started a phased process to bring the infrastructure back online. Once all networking and storage infrastructure had power restored, dependent compute scale units were then also restored to operation. As the underlying compute and storage scale units came online, dependent Azure services started to recover, but some services experienced issues coming back online.

From a Storage perspective, seven tenants were impacted – five standard storage tenants, and two premium storage tenants. While all storage data is replicated across multiple storage servers, there were cases in which all of the copies were unavailable due to failures on multiple impacted storage servers. After power restoration, storage nodes started coming back online from 15:25 UTC. Generally speaking, there were three main factors that contributed to delays in bringing storage infrastructure back to full functionality. Firstly, the hardware damaged by the data hall temperatures required extensive troubleshooting. Diagnostics were not able to identify the faults, because the storage nodes themselves were not online – as a result, our onsite datacenter team needed to remove components manually, and re-seat them one by one to identify which particular component(s) were preventing each node from booting. Secondly, several components needed to be replaced for successful data recovery and to restore impacted nodes. In order to completely recover data, some of the original/faulty components were required to be temporarily re-installed in individual servers. Thirdly, we identified that our automation was incorrectly approving stale requests, and marking some healthy nodes as unhealthy, which slowed storage recovery efforts.

From a SQL perspective, once power had fully returned to the impacted halls, service restoration was initially impacted by the slow recovery of dependent services, those being primarily Azure Standard Storage offerings. Many general purpose databases remained unavailable until those premium Azure Storage services had recovered. After storage services were >99% recovered, a single tenant ring that hosted databases failed to recover completely after the incident. This ring, hosting over ~250K databases had a mix of failure modes. Some databases may have been completely unavailable, some would have experienced intermittent connectivity issues, and some databases would have been fully available. This uneven impact profile for databases in the degraded ring, meant that it was difficult to summarize which customers were still impacted, which continued to present a challenge throughout the incident. As we attempted to migrate databases out of the degraded ring, SQL did not have well tested tools on hand that were built to move databases when the source ring was in degraded health scenario. Soon this became our largest impediment to mitigating impact. Our standard DB migration workflows are designed to contain many safety and health checks to make sure that the DB being migrated does not experience downtime during the migration. Each of these contact points from the SQL control plane to the underlying Service Fabric (which hosts the DB's compute and coordinates replicas) for the ring was another opportunity for the operation to fail or get stuck. Because every DB moved required manual mitigation via scripts, it seriously undermined our ability to move fast even once impacted DBs were identified, and DB moves were scheduled.

From a Cosmos DB perspective, the service experienced a loss of compute underpinning three clusters, and a loss of the operating system for 11 clusters due to dependencies on Azure storage. In total this mean that approximately half of Cosmos DB clusters in the Australia East region were either down or heavily degraded. Eligible accounts (multi-region with Service Managed Failover enabled) were failed over to their alternate regions to restore availability. A set of internal accounts were not originally configured for failover, so the Cosmos DB team worked with these internal service teams to configure and then failover those accounts upon request. Accounts that were not eligible had service restored to partitions once the dependent storage and compute were restored and Cosmos DB clusters recovered.

How did we respond?

30 August 2023 @ 08:41 – Voltage sag occurred on utility power line

30 August 2023 @ 08:43 – Five chillers failed to restart

30 August 2023 @ 08:45 – Two standby chillers started automatically

30 August 2023 @ 08:47 – One standby chiller tripped and went offline

30 August 2023 @ 09:41 – Onsite team arrived at the rooftop chiller area

30 August 2023 @ 09:42 – Onsite team manually restarted the five chillers as per the EOP
30 August 2023 @ 10:30 – Storage and SQL alerted by monitors about failure rates
30 August 2023 @ 10:57 – Cosmos DB Initial impact detected via monitoring
30 August 2023 @ 11:15 – Attempts to stabilize the five chillers were unsuccessful after multiple chiller restarts
30 August 2023 @ 11:20 – Chiller OEM support team arrives onsite
30 August 2023 @ 11:34 – Decision was made to shutdown infrastructure in the two affected data halls
30 August 2023 @ 12:07 – Failover initiated for eligible Cosmos DB accounts
30 August 2023 @ 12:12 – Five chillers manually restarted successfully
30 August 2023 @ 13:30 – Data hall temperature normalized
30 August 2023 @ 14:10 – Safety walkthrough completed for both data halls
30 August 2023 @ 14:25 – Decision made to start powering up hardware in the two affected data halls
30 August 2023 @ 15:10 – Power restored to all hardware
30 August 2023 @ 15:25 – Storage infrastructure started coming back online after power restoration
30 August 2023 @ 15:30 – Identified three specific storage tenants still experiencing fault codes
30 August 2023 @ 16:00 – Began manual recovery efforts for these three storage tenants
30 August 2023 @ 16:13 – Account failover completed for all Cosmos DB accounts
30 August 2023 @ 19:29 – Successfully recovered all premium storage tenants
30 August 2023 @ 20:29 – All but two SQL nodes recovered
30 August 2023 @ 22:35 – Standard storage tenants were recovered, except for one scale unit
31 August 2023 @ 04:04 – Restoration of Cosmos DB accounts to Australia East initiated
31 August 2023 @ 04:43 – Final Cosmos DB cluster recovered, restoring all traffic for accounts that were not failed over
31 August 2023 @ 08:45 – All external customer accounts back online and operating from Australia
1 September 2023 @ 06:40 – Successfully recovered all standard storage tenants

How are we making incidents like this less likely or less impactful?

Based on our initial assessment, we have already identified the following learnings from a datacenter power/cooling perspective. The Final PIR will include additional learnings and repairs based on the service-specific extended recovery timelines.

Due to the size of the datacenter campus, the staffing of the team at night was insufficient to restart the chillers in a timely manner. We have temporarily increased the team size from three to seven, until the underlying issues are better understood and appropriate mitigations can be put in place.

The EOP for restarting chillers is slow to execute for an event with such a significant blast radius. We are exploring ways to improve existing automation to be more resilient to various voltage sag event types.

Moving forward, we are evaluating ways to ensure that the load profiles of the various chiller subsets can be prioritized so that chiller restarts will be performed for the highest load profiles first.

Utilizing the playbook in sequencing workload failovers and equipment shutdown could have been prioritized differently with better insights. We are working to improve reporting on chilled water temperature, to enable more timely decisions for failover/shutdown based on thresholds.

The five chillers did not manage to restart because the corresponding pumps did not get the run signal from the chillers. This is important as it is integral to the successful restarting of the chiller units. We are partnering with our OEM vendor to investigate why the chillers did not command their respective pump to start.

One standby chiller did not automatically restart due to an unknown error. Our OEM vendor is running diagnostics to understand what caused this specific issue.

How can we make our incident communications more useful?

You can rate this PIR and provide any feedback using our quick 3-question survey: <https://aka.ms/AzPIR/VVTQ-J98>

Sat Sep 02 2023 01:35:02 GMT+1000 (Australian Eastern Standard Time)

Summary of Impact: Starting at approximately 08:30 UTC on 30 August 2023, a number of Azure customers in Australia East experienced degraded performance and availability issues for resources hosted in this region. Impact was limited to one of the three Availability Zones in a datacenter in this region. As of 16:07 UTC on 31 Aug 2023, most services were recovered.

Preliminary Root Cause: We determined a utility power surge in the Australia East region tripped a subset of the cooling units offline in one datacenter, within one of the Availability Zones. While working to restore cooling, temperatures in the datacenter increased so we proactively powered down a small subset of selected compute and storage scale units, to avoid damage to hardware. Multiple downstream services were impacted by this issue.

Mitigation: We worked on recovering the failed cooling units and reducing the overall temperature within the impacted area. Once temperature levels were within safe thresholds, we began to restore power to the affected infrastructure and started a phased process to bring this infrastructure back online. Once storage infrastructure was fully restored, dependent compute scale units were then also restored to operation. As the underlying compute and storage scale units became healthy, compute and other dependent Azure services recovered.

While we have broadly recovered, a small subset of services (SQL and Cosmos DB) are still working on post recovery checks, and we are closely monitoring the datacenter metrics for storage and compute resources to ensure they continue to show as healthy. For any residual customers with services still in the recovery process, we will continue communicating directly through the Azure Portal.

Next Steps: Next Steps: We will continue working on recovering a small number of instances still affected. Additionally:

Our services team will be completing an internal retrospective to understand the incident in more detail. We will publish a Preliminary Post Incident Review (PIR) within approximately 72 hours, to share more details on what happened and how we responded. After our internal retrospective is completed, generally within 14 days, we will publish a Final Post Incident Review with any additional details and learnings.

To get notified when that happens, and/or to stay informed about future Azure service issues, make sure that you configure and maintain Azure Service Health alerts – these can trigger emails, SMS, push notifications, webhooks, and more: <https://aka.ms/ash-alerts>.

For more information on Post Incident Reviews, refer to <https://aka.ms/AzurePIRs>. Finally, for broader guidance on preparing for cloud incidents, refer to <https://aka.ms/incidentreadiness>.

Fri Sep 01 2023 06:07:28 GMT+1000 (Australian Eastern Standard Time)

Impact Statement: Starting at approximately 08:30 UTC on 30 August 2023, a utility power surge in the Australia East region tripped a subset of the cooling units offline in one datacenter, within one of the Availability Zones. While working to restore cooling, temperatures in the datacenter increased so we proactively powered down a small subset of selected compute and storage scale units, to avoid damage to hardware. Multiple downstream services were impacted, with targeted communications being distributed via Azure Service Health.

Current Status: Having successfully recovered 99% of storage services and 99% of impacted Virtual Machines, we are beginning to see the recovery on the impacted nodes. At this stage, we believe most downstream services that are still experiencing impact are the result of dependencies on one of three services with recovery ongoing. Impact is minimal at this time and most dependent services should begin to see recovery.

Power has been restored to all clusters hosting Cosmos DB. Accounts that were not failed over should continue to see recovery in Australia East. Accounts failed over to alternate regions will continue to operate in these alternate regions; the Cosmos DB team has made additional progress in bringing the Australia East region back online.

Over 99% of impacted Azure storage accounts are now fully recovered. Due to thermal damage, we continue working on recovering a small number of resources to bring the remaining impacted storage accounts back online. We have recovered 75% of the remaining impacted resources, and as we continue making progress, additional services are displaying indications of improvement.

Azure SQL is continuing to recover impact to a single backend cluster, impacting a small subset of databases instances. Additionally, we are taking steps to reduce the overall zonal load to facilitate improved resource allocation and recovery.

Further updates on these remaining recovery efforts will be provided as events warrant.

Thu Aug 31 2023 22:55:12 GMT+1000 (Australian Eastern Standard Time)

Impact Statement: Starting at approximately 08:30 UTC on 30 August 2023, a utility power surge in the Australia East region tripped a subset of the cooling units offline in one datacenter, within one of the Availability Zones. While working to restore cooling, temperatures in the datacenter increased so we proactively powered down a small subset of selected compute and storage scale units, to avoid damage to hardware. Multiple downstream services were impacted, with targeted communications being distributed via Azure Service Health.

Current Status: Having successfully recovered 99% of storage services and 99% of impacted Virtual Machines, we are beginning to see the recovery on the impacted nodes. At this stage, we believe most downstream services that are still experiencing impact are the result of dependencies on one of three services with recovery ongoing.

Power has been restored to all clusters hosting Cosmos DB. Accounts that were not failed over should see recovery in Australia East. Accounts failed over to alternate regions will continue to operate in these alternate regions; the Cosmos DB team has begun to bring Australia East region online.

Over 99% of impacted Azure storage accounts are now fully recovered. Due to thermal damage, we continue working on recovering a small number of resources to bring the remaining impacted storage accounts back online. We have recovered 75% of the remaining impacted resources, and as we continue making progress, additional services are displaying indications of improvement.

Azure SQL is continuing to recover impact to a single backend cluster, impacting a small subset of databases instances. Additionally, we are taking steps to reduce the overall zonal load to facilitate improved resource allocation and recovery.

Further updates on these remaining recovery efforts will be provided 2 hours, or as events warrant.

Thu Aug 31 2023 20:52:21 GMT+1000 (Australian Eastern Standard Time)

Impact Statement: Starting at approximately 08:30 UTC on 30 August 2023, a utility power surge in the Australia East region tripped a subset of the cooling units offline in one datacenter, within one of the Availability Zones. While working to restore cooling, temperatures in the datacenter increased so we proactively powered down a small subset of selected compute and storage scale units, to avoid damage to hardware. Multiple downstream services were impacted, with targeted communications being distributed via Azure Service Health.

Current Status: Having successfully recovered 99% of storage services and 99% of impacted Virtual Machines, we are beginning to see the recovery on the impacted nodes. At this stage, we believe most downstream services that are still experiencing impact are the result of dependencies on one of three services with recovery ongoing.

Power has been restored to all clusters hosting Cosmos DB. Accounts that were not failed over should see recovery in Australia East. Accounts failed over to alternate regions will continue to operate in these alternate regions; the Cosmos DB team has begun to bring Australia East region online.

Over 99% of impacted Azure storage accounts are now fully recovered. Due to thermal damage, we continue working on replacing or recovering a small number of resources to bring the remaining impacted storage accounts back online. At this point we can confirm that we have recovered 50% of the remaining impacted resources, and as we continue making progress, additional services are displaying indications of improvement.

Azure SQL is continuing to recover impact to a single backend cluster, impacting a small subset of databases instances. Additionally, we are taking steps to reduce the overall zonal load to facilitate improved resource allocation and recovery.

Further updates on these remaining recovery efforts will be provided 2 hours, or as events warrant.

Thu Aug 31 2023 19:35:06 GMT+1000 (Australian Eastern Standard Time)

Impact Statement: Starting at approximately 08:30 UTC on 30 August 2023, a utility power surge in the Australia East region tripped a subset of the cooling units offline in one datacenter, within one of the Availability Zones. While working to restore cooling, temperatures in the datacenter increased so we proactively powered down a small subset of selected compute and storage scale units, to avoid damage to hardware. Multiple downstream services were impacted, with

targeted communications being distributed via Azure Service Health.

Current Status: Having successfully recovered 99% of storage services and 99% of impacted Virtual Machines, we are beginning to see the recovery on the impacted nodes. At this stage, we believe most downstream services that are still experiencing impact are the result of dependencies on one of three services with recovery ongoing.

Power has been restored to all clusters hosting Cosmos DB. Accounts that were not failed over should see recovery in Australia East. Accounts failed over to alternate regions will continue to operate in these alternate regions; the Cosmos DB team has begun to bring Australia East region online.

Over 99% of impacted Azure storage accounts are now fully recovered. Due to thermal damage, we continue working on replacing or recovering a small number of resources to bring the remaining impacted storage accounts back online.

Azure SQL is continuing to recover impact to a single backend cluster, impacting a small subset of databases instances. Additionally, we are taking steps to reduce the overall zonal load to facilitate improved resource allocation and recovery.

Further updates on these remaining recovery efforts will be provided in 60 minutes, or as events warrant.

Thu Aug 31 2023 17:53:12 GMT+1000 (Australian Eastern Standard Time)

Impact Statement: Starting at approximately 08:30 UTC on 30 August 2023, a utility power surge in the Australia East region tripped a subset of the cooling units offline in one datacenter, within one of the Availability Zones. While working to restore cooling, temperatures in the datacenter increased so we proactively powered down a small subset of selected compute and storage scale units, to avoid damage to hardware. Multiple downstream services were impacted, with targeted communications being distributed via Azure Service Health.

Current Status: Having successfully recovered 99% of storage services and 99% of impacted Virtual Machines, we are actively investigating individual downstream services to confirm their recovery status and mitigate remaining issues. At this stage, we believe most downstream services that are still experiencing impact are the result of dependencies on one of three services with investigations ongoing.

Power has been restored to all clusters hosting Cosmos DB. Accounts that were not failed over should see recovery in Australia East. Accounts failed over to alternate regions will continue to operate in these alternate regions; the Cosmos DB team has begun onlining the Australia East region for accounts that were failed over earlier.

Over 99% of impacted Azure storage accounts are now fully recovered, a small number resources are currently being replaced or repaired due to thermal damage in order to bring the remaining impacted storage accounts back online.

Azure SQL is continuing to recover impact to a single backend cluster, impacting a small subset of databases instances. Additionally, we are taking steps to reduce the overall zonal load to facilitate improved resource allocation and recovery.

Further updates on these remaining recovery efforts will be provided in 60 minutes, or as events warrant.

Thu Aug 31 2023 16:55:41 GMT+1000 (Australian Eastern Standard Time)

Impact Statement: Starting at approximately 08:30 UTC on 30 August 2023, a utility power surge in the Australia East region tripped a subset of the cooling units offline in one datacenter, within one of the Availability Zones. While working to restore cooling, temperatures in the datacenter increased so we proactively powered down a small subset of selected compute and storage scale units, to avoid damage to hardware. Multiple downstream services were impacted, with targeted communications being distributed via Azure Service Health.

Current Status: Having successfully recovered 99% of storage services and 99% of impacted Virtual Machines, we are actively investigating individual downstream services to confirm their recovery status and mitigate remaining issues. At this stage, we believe most downstream services that are still experiencing impact are the result of dependencies on one of three services with investigations ongoing.

Power has been restored to 100% of Cosmos DB clusters. Accounts who were not failed over should see recovery in Australia East. The Cosmos DB team has begun onlining this region for accounts that were failed over earlier.

Over 99% of impacted Azure storage accounts are now fully recovered, a small number of resources are currently being replaced or repaired due to thermal damage in order to bring the remaining impacted storage accounts back online.

Azure SQL is continuing to recover impact to a single backend cluster, impacting a small subset of databases instances. Additionally, we are taking steps to reduce the overall zonal load to facilitate improved resource allocation and recovery.

Further updates on these remaining recovery efforts will be provided in 60 minutes, or as events warrant.

Thu Aug 31 2023 15:45:14 GMT+1000 (Australian Eastern Standard Time)

Impact Statement: Starting at approximately 08:30 UTC on 30 August 2023, a utility power surge in the Australia East region tripped a subset of the cooling units offline in one datacenter, within one of the Availability Zones. While working to restore cooling, temperatures in the datacenter increased so we proactively powered down a small subset of selected compute and storage scale units, to avoid damage to hardware. Multiple downstream services were impacted, with targeted communications being distributed via Azure Service Health.

Current Status: Having successfully recovered 99% of storage services and 99% of impacted Virtual Machines, we are actively investigating individual downstream services to confirm their recovery status and mitigate remaining issues. At this stage, we believe most downstream services that are still experiencing impact are the result of dependencies on one of three services with investigations ongoing.

Over 90% of Cosmos DB clusters in the Australia East region have been successfully recovered. Cosmos DB Accounts, that were not failed over to alternate read/write regions, should now begin to see signs of recovery. Once all clusters are fully restored, the Cosmos DB team will initiate the process of bringing this region back online for accounts that were previously failed over.

Over 99% of impacted Azure storage accounts are now fully recovered, a small number of resources are currently being replaced or repaired due to thermal damage in order to bring the remaining impacted storage accounts back online.

Azure SQL is continuing to recover impact to a single backend cluster, impacting a small subset of databases instances. Additionally, we are taking steps to reduce the overall zonal load to facilitate improved resource allocation and recovery.

We have assessed that achieving complete mitigation will require additional amount of time. Further updates on these remaining recovery efforts will be provided in 60 minutes, or as events warrant.

Thu Aug 31 2023 14:38:57 GMT+1000 (Australian Eastern Standard Time)

Impact Statement: Starting at approximately 08:30 UTC on 30 August 2023, a utility power surge in the Australia East region tripped a subset of the cooling units offline in one datacenter, within one of the Availability Zones. While working to restore cooling, temperatures in the datacenter increased so we proactively powered down a small subset of selected compute and storage scale units, to avoid damage to hardware. Multiple downstream services were impacted, with targeted communications being distributed via Azure Service Health.

Current Status: Having successfully recovered 99% of storage services and 99% of impacted Virtual Machines, we are actively investigating individual downstream services to confirm their recovery status and mitigate remaining issues. At this stage, we believe most downstream services that are still experiencing impact are the result of dependencies on one of three services with investigations ongoing.

Over 90% of Cosmos DB clusters in the Australia East region have been successfully recovered. Cosmos DB Accounts, that were not failed over to alternate read/write regions, should now begin to see signs of recovery. Once all clusters are fully restored, the Cosmos DB team will initiate the process of bringing this region back online for accounts that were previously failed over.

Over 99% of impacted Azure storage accounts are now fully recovered, a small number of resources are currently being replaced or repaired due to thermal damage in order to bring the remaining impacted storage accounts back online.

Azure SQL is continuing to recover impact to a single backend cluster, impacting a small subset of databases instances. Additionally, we are taking steps to reduce the overall zonal load to facilitate improved resource allocation and recovery.

Further updates on these remaining recovery efforts will be provided in 60 minutes, or as events warrant.

Thu Aug 31 2023 13:36:16 GMT+1000 (Australian Eastern Standard Time)

Impact Statement: Starting at approximately 08:30 UTC on 30 August 2023, a utility power surge in the Australia East region tripped a subset of the cooling units offline in one datacenter, within one of the Availability Zones. While working to restore cooling, temperatures in the datacenter increased so we proactively powered down a small subset of selected compute and storage scale units, to avoid damage to hardware. Multiple downstream services were impacted, with targeted communications being distributed via Azure Service Health.

Current Status: While we have successfully recovered 99% of storage services and impacted Virtual Machines, we continue to actively investigate individual downstream services to confirm their recovery status and mitigate remaining issues. At this stage, we believe most downstream services that are still experiencing impact are the result of dependencies on one of the three services mentioned below, with investigations ongoing.

Storage - Our Storage team is making progress with the final remaining storage scale unit that is still experiencing isolated issues. We have engaged our onsite datacenter team to support replacing drives as needed.

SQL - Our SQL team is working to mitigate one final cluster that is experiencing a capacity issue, due to several Service Fabric nodes that have not fully recovered. We are rebalancing capacity to mitigate.

Cosmos DB - Our Cosmos DB team continues to investigate why some services have not yet recovered fully while the majority of customers and services are already mitigated.

A further update on the remaining investigation will be provided within 60 minutes, or as events warrant.

Thu Aug 31 2023 12:28:49 GMT+1000 (Australian Eastern Standard Time)

Impact Statement: Starting at approximately 08:30 UTC on 30 August 2023, a utility power surge in the Australia East region tripped a subset of the cooling units offline in one datacenter, within one of the Availability Zones. While working to restore cooling, temperatures in the datacenter increased so we proactively powered down a small subset of selected compute and storage scale units, to avoid damage to hardware. Multiple downstream services were impacted, with targeted communications being distributed via Azure Service Health.

Current Status: While we have successfully recovered 99% of storage services and impacted Virtual Machines, we continue to actively investigate individual downstream services to confirm their recovery status and mitigate remaining issues. At this stage, we believe most downstream services that are still experiencing impact are the result of dependencies on one of the three services mentioned below, with investigations ongoing.

Storage - Our Storage team is making progress with the final remaining storage scale unit that is still experiencing isolated issues. We have engaged our onsite datacenter team to support replacing drives as needed.

SQL - Our SQL team is working to mitigate one final cluster that is experiencing a capacity issue, due to several Service Fabric nodes that have not fully recovered. We are rebalancing capacity to mitigate.

Cosmos DB - Our Cosmos DB team continues to investigate why some services have not yet recovered fully while the majority of customers and services are already mitigated.

The next update will be provided within 60 minutes, or as events warrant.

Thu Aug 31 2023 11:10:00 GMT+1000 (Australian Eastern Standard Time)

Impact Statement: Starting at approximately 08:30 UTC on 30 August 2023, a utility power surge in the Australia East region tripped a subset of the cooling units offline in one datacenter, within one of the Availability Zones. While working to restore cooling, temperatures in the datacenter increased so we proactively powered down a small subset of selected compute and storage scale units, to avoid damage to hardware. Multiple downstream services were impacted, with targeted communications being distributed via Azure Service Health.

Current Status: Having successfully recovered 99% of storage services and 99% of impacted Virtual Machines, we are actively investigating individual downstream services to confirm their recovery status and mitigate remaining issues. At this stage, we believe most downstream services that are still experiencing impact are the result of dependencies on one of three services with investigations ongoing. Firstly, our Storage team are making progress with the final remaining storage scale unit that is still experiencing isolated issues - we have engaged our onsite datacenter team to support replacing drives as needed. Secondly, our SQL team are working to mitigate one final cluster that is experiencing a capacity issue, due to several Service Fabric nodes that have not fully recovered - we are rebalancing capacity to mitigate. Finally, our Cosmos DB team continue to investigate why some services have not yet recovered fully. While the majority of customers

and the majority of services are already mitigated, further updates on these remaining investigations will be provided in 60 minutes, or as events warrant.

Thu Aug 31 2023 09:49:39 GMT+1000 (Australian Eastern Standard Time)

Impact Statement: Starting at approximately 08:30 UTC on 30 August 2023, a utility power surge in the Australia East region tripped a subset of the cooling units offline in one datacenter, within one of the Availability Zones. While working to restore cooling, temperatures in the datacenter increased so we proactively powered down a small subset of selected compute and storage scale units, to avoid damage to hardware. Multiple downstream services were impacted, with targeted communications being distributed via Azure Service Health.

Current Status: Having successfully recovered 99% of storage services and 99% of impacted Virtual Machines, we are actively investigating individual downstream services to confirm their recovery status and mitigate remaining issues. At this stage, we believe most downstream services that are still experiencing impact are the result of dependencies on one of three services with investigations ongoing. Firstly, our Storage team are making progress with the final remaining storage scale unit that is still experiencing isolated issues - we have engaged our onsite datacenter team to support replacing drives as needed. Secondly, our SQL team are working to mitigate one final cluster that is experiencing a capacity issue, due to several Service Fabric nodes that have not fully recovered - we are rebalancing capacity to mitigate. Finally, our Cosmos DB team continue to investigate why some services have not yet recovered fully. While the majority of customers and the majority of services are already mitigated, further updates on these remaining investigations will be provided in 60 minutes, or as events warrant.

Thu Aug 31 2023 08:48:09 GMT+1000 (Australian Eastern Standard Time)

Impact Statement: Starting at approximately 08:30 UTC on 30 August 2023, a utility power surge in the Australia East region tripped a subset of the cooling units offline in one datacenter, within one of the Availability Zones. While working to restore cooling, temperatures in the datacenter increased so we proactively powered down a small subset of selected compute and storage scale units, to avoid damage to hardware. Multiple downstream services were impacted, with targeted communications being distributed via Azure Service Health.

Current Status: With 99% of storage services and 99% of impacted Virtual Machines back online and healthy, we are actively investigating remaining issues with individual downstream services to confirm their recovery status. Our Storage team are making progress on one specific storage scale unit that is still experiencing isolated issues. Our SQL team are investigating a potential issue with an underlying Service Fabric dependency. Our Cosmos DB team are investigating why some services have not fully recovered. Despite these remaining investigations, the majority of customers and services should already be recovered. Further updates will be provided in 60 minutes, or as events warrant.

Thu Aug 31 2023 07:50:51 GMT+1000 (Australian Eastern Standard Time)

Impact Statement: Starting at approximately 08:30 UTC on 30 August 2023, a utility power surge in the Australia East region tripped a subset of the cooling units offline in one datacenter, within one of the Availability Zones. While working to restore cooling, temperatures in the datacenter increased so we proactively powered down a small subset of selected compute and storage scale units, to avoid damage to hardware.

Multiple downstream services were impacted, with targeted communications being distributed via Azure Service Health. Impact to services is limited to Australia East, except for Azure Kubernetes Service (AKS) which has impact in both Australia East and Australia Southeast due to a dependency in the former.

Current Status: With 99% of storage services and 99% of impacted Virtual Machines back online and healthy, we are now supporting individual downstream services to confirm their recovery status. We are aware of one specific storage scale unit that is still experiencing isolated issues, but the majority of customers and services should already be recovered. Beyond this known storage issue, we are investigating which services are still not fully mitigated and why. Further updates will be provided in 60 minutes, or as events warrant.

Thu Aug 31 2023 06:54:44 GMT+1000 (Australian Eastern Standard Time)

Impact Statement: Starting at approximately 08:30 UTC on 30 August 2023, a utility power surge in the Australia East region tripped a subset of the cooling units offline in one datacenter, within one of the Availability Zones. While working to restore cooling, temperatures in the datacenter increased so we proactively powered down a small subset of selected compute and storage scale units, to avoid damage to hardware.

Multiple downstream services were impacted, with targeted communications being distributed via Azure Service Health. Impact to services is limited to Australia East, except for Azure Kubernetes Service (AKS) which has impact in both Australia East and Australia Southeast due to a dependency in the former. If your workloads are protected by Azure Site Recovery or Azure Backup, and you need critical services back online before all services in this datacenter are fully recovered, we recommend either to initiate a failover to the recovery region or recover using Cross Region Restore. Note that any new allocation requests for the Australia East region will automatically avoid the impacted scale units.

Current Status: We are in the final phases of restoring core services, and expect that the vast majority of remaining impacted services should be back online in the next hour. After restoring power and stabilizing temperatures, all network infrastructure and 99% of storage services are back online. All premium disk storage has fully recovered, we continue to work towards mitigating the final remaining storage devices. The vast majority of underlying compute services are back online, with more than 99% of Virtual Machines (VMs) that were impacted now back online and healthy.

While many customers and services have already recovered, we are now prioritizing our investigations with the remaining downstream impacted services. We expect that these remaining services should be back online and healthy within the next hour. Further updates will be provided in 60 minutes, or as events warrant.

Thu Aug 31 2023 05:55:40 GMT+1000 (Australian Eastern Standard Time)

Impact Statement: Starting at approximately 08:30 UTC on 30 August 2023, a utility power surge in the Australia East region tripped a subset of the cooling units offline in one datacenter, within one of the Availability Zones. While working to restore cooling, temperatures in the datacenter increased so we proactively powered down a small subset of selected compute and storage scale units, to avoid damage to hardware.

Multiple downstream services were impacted, with targeted communications being distributed via Azure Service Health. Impact to services is limited to Australia East, except for Azure Kubernetes Service (AKS) which has impact in both Australia East and Australia Southeast due to a dependency in the former. If your workloads are protected by Azure Site Recovery or Azure Backup, and you need critical services back online before all services in this datacenter are fully recovered, we recommend either to initiate a failover to the recovery region or recover using Cross Region Restore. Note that any new allocation requests for the Australia East region will automatically avoid the impacted scale units.

Current Status: We have made significant progress in restoring core services, and expect that the vast majority of remaining services should be back online in the next 1-2 hours. After restoring power and stabilizing temperatures, all network infrastructure and 95% of storage services are back online. All premium disk storage has fully recovered, we continue to work towards mitigating the final remaining storage devices. The majority of underlying compute services are back online, with more than 85% of Virtual Machines (VMs) that were impacted now back online and healthy. For the remaining VMs, we are investigating potential issues in connecting to their corresponding storage services.

While many customers have already recovered, we continue to work with downstream impacted services to ensure that they are coming back online in the next 1-2 hours as expected. Further updates will be provided in 60 minutes, or as events warrant.

Thu Aug 31 2023 04:59:04 GMT+1000 (Australian Eastern Standard Time)

Impact Statement: Starting at approximately 08:30 UTC on 30 August 2023, a utility power surge in the Australia East region tripped a subset of the cooling units offline in one datacenter, within one of the Availability Zones. While working to restore cooling, temperatures in the datacenter increased so we proactively powered down a small subset of selected compute and storage scale units, to avoid damage to hardware.

Multiple downstream services were impacted, with targeted communications being distributed via Azure Service Health. Impact to services is limited to Australia East, except for Azure Kubernetes Service (AKS) which has impact in both Australia East and Australia Southeast due to a dependency in the former. If your workloads are protected by Azure Site Recovery or Azure Backup, and you need critical services back online before all services in this datacenter are fully recovered, we recommend either to initiate a failover to the recovery region or recover using Cross Region Restore. Note that any new allocation requests for the Australia East region will automatically avoid the impacted scale units.

Current Status: Mitigation efforts are continuing, we have made significant progress in restoring core services, and we expect that the vast majority of remaining services should be back online in the next 2-3 hours. After restoring power and stabilizing temperatures, all network infrastructure and 95% of storage services are back online. All premium disk storage has fully recovered, we continue to work towards mitigating the final remaining storage devices. The majority of underlying compute services are back online, with more than 85% of Virtual Machines that were impacted now back online and healthy. As a result, many customers of these services have already recovered - but we continue to work with downstream impacted services to ensure that they are coming back online in the next 2-3 hours as expected. Further updates will be provided in 60 minutes, or as events warrant.

Thu Aug 31 2023 04:07:32 GMT+1000 (Australian Eastern Standard Time)

Impact Statement: Starting at approximately 08:30 UTC on 30 August 2023, a utility power surge in the Australia East region tripped a subset of the cooling units offline in one of the Availability Zones. While working to restore cooling, temperatures in the datacenter increased so we proactively powered down a small subset of selected compute and storage scale units to avoid damage to hardware. All impacted storage and compute scale units were in the same datacenter, within one of the region's three Availability Zones (AZs).

Multiple downstream services have been identified as impacted, with targeted communications being distributed via Azure Service Health. Impact to services is limited to Australia East, except for Azure Kubernetes Service (AKS) which

has impact in both Australia East and Australia Southeast due to a dependency in the former. If your workloads are protected by Azure Site Recovery or Azure Backup, and you need critical services back online before this datacenter is fully recovered, we recommend to either initiate a failover to the recovery region or recover using Cross Region Restore. Note that any new allocations for resources in the Australia East region will automatically avoid the impacted scale units.

Current Status: Mitigation efforts are continuing, we have made significant progress in restoring core services but we are not able to provide a mitigation ETA at this time. Power to all hardware has been restored, temperatures in the impacted datacenter have stabilized. All network infrastructure is back online. The majority of storage devices are back online, we are validating issues with a few remaining storage nodes. The majority of underlying compute services are back online, with more than 75% of Virtual Machines that were impacted back online and healthy. While many customers of these core services have seen signs of recovery, we continue to work with downstream impacted services to ensure that they are coming back online as expected. Further updates will be provided in 60 minutes, or as events warrant.

Thu Aug 31 2023 03:06:34 GMT+1000 (Australian Eastern Standard Time)

Impact Statement: Starting at approximately 08:30 UTC on 30 August 2023, a utility power surge in the Australia East region tripped a subset of the cooling units offline in one of the Availability Zones. While working to restore cooling, temperatures in the datacenter increased so we proactively powered down a small subset of selected compute and storage scale units to avoid damage to hardware. All impacted storage and compute scale units are in the same datacenter, within one of the region's three Availability Zones (AZs). Multiple downstream services have been identified as impacted, with targeted communications being distributed via Azure Service Health.

If your workloads are protected by Azure Site Recovery or Azure Backup, and you need critical services back online before this datacenter is fully recovered, we recommend to either initiate a failover to the recovery region or recover using Cross Region Restore. Note that any new allocations for resources in the Australia East region will automatically avoid the impacted scale units.

Current Status: We are not able to provide a mitigation ETA at this time, but power to all hardware has been restored, and temperatures in the impacted datacenter have been stabilized. We are now making progress on service recovery - cautiously, starting with core services. The vast majority of network infrastructure is back online, and storage device recovery has started. Due to the nature of this issue our storage scale units are expected to require additional recovery efforts to ensure that all resources return in a consistent state. As service recovery continues, some customers may start experiencing signs of recovery. Further updates will be provided in 60 minutes, or as events warrant.

Thu Aug 31 2023 01:58:46 GMT+1000 (Australian Eastern Standard Time)

Impact Statement: Starting at approximately 08:30 UTC on 30 August 2023, a utility power surge in the Australia East region tripped a subset of the cooling units offline in one of the Availability Zones. While working to restore the cooling units, temperatures in the datacenter increased so we have proactively powered down a small subset of selected compute and storage scale units to avoid damage to hardware and reduce cooling system load. All impacted storage and compute scale units are in the same datacenter, within one of the region's three Availability Zones (AZs). Multiple downstream services have been identified as impacted.

Current Status: We do not have an exact ETA at this time, but temperatures in the impacted datacenter have been stabilized. The Azure service recovery process has commenced and is expected to progress over a number of hours. Due to the nature of this issue our storage scale units are expected to require additional recovery efforts to ensure all resources return in a consistent state. Note that any new allocations for resources will automatically avoid the impacted scale units. If your workloads are protected by Azure Site Recovery or Azure Backup, we recommend to either initiate a

failover to the recovery region or recover using Cross Region Restore.

All impacted hardware previously powered off as a preventative measure has now been powered back on. We continue our mitigation efforts to bring all affected services back online, and as this continues, some customers may start experiencing signs of recovery. Further updates will be provided in 60 minutes, or as events warrant.

Thu Aug 31 2023 01:01:02 GMT+1000 (Australian Eastern Standard Time)

Impact Statement: Starting at approximately 08:30 UTC on 30 August 2023, a utility power surge in the Australia East region tripped a subset of the cooling units offline in one of the Availability Zones. While working to restore the cooling units, temperatures in the datacenter increased so we have proactively powered down a small subset of selected compute and storage scale units to avoid damage to hardware and reduce cooling system load. All impacted storage and compute scale units are in the same datacenter, within one of the region's three Availability Zones (AZs). Multiple downstream services have been identified as impacted.

Current Status: We do not have an exact ETA at this time, but temperatures in the impacted datacenter have been stabilized. The Azure service recovery process has commenced and is expected to progressively return over a number of hours. Due to the nature of this issue our storage scale units are expected to require additional recovery efforts to ensure all resources return in a consistent state. Note that any new allocations for resources will automatically avoid the impacted scale units. If your workloads are protected by Azure Site Recovery or Azure Backup, we recommend to either initiate a failover to the recovery region or recover using Cross Region Restore.

Our mitigation efforts to restore our services are ongoing, and further updates will be provided in 1 hour or as events warrant.

Wed Aug 30 2023 23:34:17 GMT+1000 (Australian Eastern Standard Time)

Impact Statement: Starting at approximately 08:30 UTC on 30 August 2023, a utility power surge in the Australia East region tripped a subset of the cooling units offline in one of the Availability Zones. While working to restore the cooling units, temperatures in the datacenter increased so we have proactively powered down a small subset of selected compute and storage scale units to avoid damage to hardware and reduce cooling system load. All impacted storage and compute scale units are in the same datacenter, within one of the region's three Availability Zones (AZs). Multiple downstream services have been identified as impacted.

Current Status: We do not have an exact ETA at this time, but temperature in the impacted datacenter have been stabilized. The Azure service recovery process has commenced and is expected to progressively return over a number of hours. Due to the nature of this issue our storage scale units are expected to require additional recovery efforts to ensure all resources return in a consistent state. Note that any new allocations for resources will automatically avoid the impacted scale units. If your workloads are protected by Azure Site Recovery or Azure Backup, we recommend to either initiate a failover to the recovery region or recover using Cross Region Restore.

Further updates will be provided in an hour or as events warrant.

Wed Aug 30 2023 21:48:25 GMT+1000 (Australian Eastern Standard Time)

Summary of Impact: Starting at 08:30 UTC on 30 August 2023, a subset of customers with workloads hosted in the Australia East may be experiencing difficulties accessing and managing resources deployed in this region.

Current Status: We are experiencing impact related to a cooling issue in a section of a datacentre in Australia East. This is resulting in connectivity and availability issues for services with dependencies on storage or compute in this section. More updates will be provided in an hour or as events warrant.

Wed Aug 30 2023 21:36:34 GMT+1000 (Australian Eastern Standard Time)

Impact statement: Starting at 08:30 UTC on 30 August 2023, a subset of customers with workloads hosted in the Australia East region may be experiencing difficulties accessing and managing resources deployed in these regions.

Current Status: We are actively working on a cooling event which has impacted a specific datacenter in the Australia East region. The result of this event is that resources might experience unexpected restarts. Further updates will be provided in an hour or as events warrant.